

| Requirements for electronic non-dimmable control gears for fluorescent lamps and LED | | | Version 14 |
|--|--|---|--|
| Manufacturer: DOTLUX GmbH Richard-Stücklen-Straße 7 91781 Weißenburg Bay. | Type / Description: Control gear: _____ 5414-030080 | | Manufacturer information Complies: YES/NO |
| Specifications: | CEAG data: | Explanation: | |
| Control gear suitable for a DC voltage range: | 186V - 260V DC (for Lead-Battery) | Possible voltage range of the battery in emergency mode. (Not for AT-S ⁺ Systems required) | YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> |
| Control gear compatible with the switch-over time of the system? | Switch-over time: 180 ms - 450 ms | Typical switch-over time of CEAG systems between mains supply and emergency power supply | YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> |
| Starting behavior of the control gear: | Stable current consumption after less than 1.6 sec. maximum. | A stable operation of the control gear after 1.6 seconds of start up is required for the right functionality of the individual monitoring. With max. 20 luminaires for one current circuit: ΔI in sum < 250 mA are allowed | YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> |
| Control gear compatible with CEAG STAR-Technology: | Phase-cut telegram (PAT): max. 30 phases (half waves) with max. 60° phase-cuts | During the CEAG STAR switching process, up to 30 half-waves are cut at a maximum of 60°. The control gear must not exhibit any malfunctions such as switching off, flickering | YES <input type="checkbox"/> NO <input type="checkbox"/> |
| only for fluorescent lamps: Control gear complies with the standard: | DIN EN 60929 | AC and/or DC-supplied electronic control gear for tubular fluorescent lamps - Performance requirements | YES <input type="checkbox"/> NO <input type="checkbox"/> |
| only for fluorescent lamps: Control gear complies with the standard: | DIN EN 61347-2-3 (incl. Attachment J) | Particular requirements for AC and/or DC supplied electronic control gear for fluorescent lamps | YES <input type="checkbox"/> NO <input type="checkbox"/> |
| only for LED: Control gear complies with the standard: | DIN EN 62384 | AC or DC supplied electronic control gear for LED modules - Performance requirements | YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> |
| only for LED: Control gear complies with the standard: | DIN EN 61347-2-13 | Particular requirements for AC or DC supplied electronic control gear for LED modules | YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> |
| Control gear complies with the standard: | DIN EN 55015 (Measured in AC and DC) | Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment | YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> |
| Control gear complies with the standard: | DIN EN 61000-3-2, Pkt. 7.3 a.) | see *Important note! | YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> |
| Control gear complies with the standard: | DIN EN 61547 | Equipment for general lighting purposes - EMC immunity requirements | YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> |
| Note: The labeling "according to VDE 0108" is not meaningful, because this is not a control gear standard! | | | |
| Specifications: | CEAG data: | Explanation: | Manufacturer information: |
| Important for functiontest: Voltage-dependent Input current of the control gear incl. LED in DC and AC operation: | V-CG-S2: >9,4 mA or >12,7 mA = OK V-CG-S: >16 mA or >47 mA = OK V-CG-SE: >16 mA or >47 mA = OK V-CG-SUW: >47 mA = OK CG-K: >16 mA or >47 mA = OK | Minimum current of the LED driver with LED module to GOOD detection via the monitoring module. In the voltage range of 189 - 264V AC on AT-S ⁺ or 186 - 260V DC on ZB-S/LP-STAR the input current must be higher than the specified current values. see *Important note! | AC: _____ (AT-S ⁺) DC: _____ (ZB-S/LP-STAR) |
| Important for functiontest: Voltage-dependent No-load current of the control gear (without or defect LED module) in DC and AC - operation*: | V-CG-S2: <5,8 mA or <7,9 mA = n.OK V-CG-S: <10 mA or <28 mA = n.OK V-CG-SE: <10 mA or <28 mA = n.OK V-CG-SUW: <28 mA = n.OK CG-K: <10 mA or <28 mA = n.OK | Maximal current of the LED driver with LED module for BAD detection via the monitoring module. In the voltage range of 189 - 264V AC on AT-S ⁺ or 186 - 260V DC on ZB-S/LP-STAR the input current must be lower than the specified current values. see *Important note! | AC: _____ (AT-S ⁺) DC: _____ (ZB-S/LP-STAR) |
| Important for the power consumption of addressable ballast: | V-CG-S2 = 30 A V-CG-S = 30 A V-CG-SE = 30 A V-CG-SUW = 80 A CG-K = 30 A | The max. inrush current of each monitoring module has to be considered! | AC: _____ (AT-S ⁺) DC: _____ (ZB-S/LP-STAR) |
| Note: Important for the planning - Max. no. Of luminaires per circuit | | | |
| Important for the contact load SKU: Max. inrush current of each luminaire in AC operation | Max. permitted inrush current per circuit: SKU 2 x 3A (CG) => 120 A SKU 1 x 6A (CG) => 180 A SKU 4 x 1,5A CG-S => 60 A SKU 2 x 3A CG-S => 250 A SKU 1 x 6A CG-S => 250 A SOU CG-S // S ⁺ => 250 A SU S ⁺ => 250 A | The declaration of the inrush current of the luminaire above is important, to calculate the max. possible luminaires on one circuit, to consider the max. contact load limitation of the circuit. | |
| Luminaires for emergency lighting must comply with DIN EN 60598-2-22 (Particular requirements -Luminaires for emergency lighting) *Important note! For AT-S ⁺ systems and for battery systems (ZB-S / LP-STAR) with active preliminary time for AC about 300 seconds (EOL detection of T5 lamps) for the function test, the current consumption must be sinusoidal, t.m. all control gears (<25W as well) must have an active PFC (Power Factor Correction)! See DIN EN 61000-3-2, Pkt. 7.3 a.) Note EOL (End of Life) detection (T5 > 14Watt): The AC preliminary time is valid for the complete system (e.g. ZB-S), not possible for individual circuits. The modules of the V-CG-S series monitor the current consumption on the primary side of the control gear for LED modules within the specified limits. Failures of individual LEDs (low-impedance) on the secondary side do not inevitably lead to a modification of current consumption on the primary side, and in such cases cannot be detected as a failure. | | | |